

Constituent	Units	MRL	Cherry Valley Well 1	Cherry Valley Well 2	BCVWD 4A	BCVWD 5	BCVWD 16	BCVWD 21	BCVWD 21 (Duplicate)	Bonita Vista Water District #1	Bonita Vista Water District #2	Bonita Vista Water District #3
Acetaminophen	ng/L	1	ND (M2)	ND	ND	ND	ND	ND	ND	ND (M2)	1.5	ND
Amoxicillin	ng/L	1	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA
Caffeine	ng/L	1	ND (M2)	ND	ND	ND	NA	ND	ND	ND	ND	ND
Cotinine	ng/L	1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Estradiol	ng/L	1	ND (M2L1)	ND	1.8	ND	ND	ND	1.4	ND	ND	ND
Fluoxetine	ng/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Gemfibrozil	ng/L	1	ND (L1)	ND (L1)	ND (L1)	ND (L1)	ND (L1)	ND	ND (L1)	ND (M1)	ND	ND
Ibuprofen	ng/L	1	ND (M2)	ND	ND	ND	ND	ND	ND	17 (M2)	148	7.6
Iopromide	ng/L	5	ND (M2)	ND (L1)	ND (L1)	ND (L1)	ND (L1)	ND (L1)	ND	ND (M1)	ND	ND
Progesterone	ng/L	1	ND (M2)	1.5	ND	ND	ND	ND	ND	NA	NA	NA
Sulfamethoxazole	ng/L	1	ND (M2)	26	ND	ND	ND	ND	ND	51 (M2)	ND	4.2
Testosterone	ng/L	1	ND (M2)	ND	ND	ND	ND	ND	ND	4.4	ND	ND
Triclosan	ng/L	5	ND (M2)	ND	ND	ND	ND	ND	ND	ND (M2)	ND	ND
Trimethoprim	ng/L	1	ND (M2)	ND	ND	ND	ND	ND	ND	ND	ND	ND

L1-The associated blank spike recovery was above laboratory acceptance limits.

M1 - Matrix spike recovery was high, the method control sample recovery was acceptable.

M2- Matrix spike recovery was low, the method control sample recovery was acceptable.